

No.	QUESTIONS	ANSWERS
1	Please specify which functions are intended for the "Rooms for RIX APRON employees" of 25 m ² tower 4th floor / tower 2nd level?	Rest-room and locker room: <ul style="list-style-type: none"> - Size of the room no less than 25 m². - Not far from the operative work hall. - Place for lockers for employees. - Kitchenette (with cold and hot water, sewerage). - Entrance control system. - Individually controlled air-conditioning, heating and ventilation system.
2	Can the "Room for RIX APRON staff" with an area of 25m ² be designed as a communicating room which gives access to the room "RIX APRON" with 4 work places?	The lounge is intended for staff where to spend time during the breaks. According to the DFS recommendations, it is advisable to place the lounge in the quietest zone on the floor, even fitting it with lockable doors. In other words, it should not be a communicating room.
3	Is it acceptable that the sections on the panels are in scale 1: 250 or should they be in scale 1: 200 as defined in the Brief?	Please, adhere to the scale defined in the Competition Brief.